

Village of Elk Rapids
Antrim County, Michigan
Water System Improvements

PROJ #2016150004.03	ADDENDUM #1	DATE: 07/18/2017
---------------------	-------------	------------------

NOTICE: This Addendum No.1, issued in accordance with the Contract Documents, is incorporated into the Contract Documents and supersedes and updates all conflicting information and is hereby amended in certain particulars as follows:

Date: July 18, 2017

CHANGES TO THE CONTRACT DOCUMENTS:

1. Bid form clarification (Items 32 thru 36), PVC Sanitary Sewer various sizes – Limits of replacement of sanitary sewer at water main crossings includes up to five feet beyond the limits of the asphalt removal/replacement or if possible within the limits of the asphalt removal/replacement.

CHANGES TO THE PLANS:

1. Where noted on plans, "SALVAGE EXISTING VALVE FOR OWNER". – Replace with, "REMOVE VALVE BOX AND LID AND PROVIDE TO OWNER. ABANDON VALVE IN PLACE."
2. Where noted on plans, "CUT IN VALVE," shall mean the main will be shut-down, a length of water main valve removed to suit new valve, and tie-in sleeves used to add a valve to an existing watermain.

ADDENDUM ACKNOWLEDGMENT:

This Addendum No. 1 shall be attached to and shall become a part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may result in the rejection of the Bid.

END SECTION

DISTRIBUTION: (via email)

All Plan Holders
Brad Kluczynski, Village of Elk Rapids
File