

Odawa Casino Resort  
Emmet County, Michigan  
Surge Tank Addition

PROJ #2016041001.00	ADDENDUM #2	DATE:07/11/17
---------------------	-------------	---------------

NOTICE: This Addendum No.2, issued in accordance with the Contract Documents, is incorporated into the Contract Documents and supersedes and updates all conflicting information and is hereby amended in certain particulars as follows:

Date: July 11, 2017

**CHANGES TO THE CONTRACT DOCUMENTS:**

1. Wastewater Treatment Plant – Bid Form
  - a. Article 7- 7.01 **STRIKE** items 7.01.H, 7.01.I, 7.01.J

**CHANGES TO THE PLANS:**

1. M-6 On First Floor Piping Plan, in the new building addition, the call out for an “ 8” PLUG VALVE(TYP OF 2)” REPLACE with “ 8” GATE VALVE (TYP OF 2)”
2. A-6: **STRIKE** “Refer to Structural” under “Concrete Footing”, **ADD** “Footing to be 2’ wide, 1’ tall with 2(two) #5’s continuous”
3. A-6 **ADD** “Note: Single Ply Membrane roof to match existing. Existing plans show roof to be Firestone EPDM Fully Adhered system over insulation panels. Contractor to field verify prior to ordering.”

**ADDENDUM ACKNOWLEDGMENT:**

This Addendum No. 2 shall be attached to and shall become a part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may result in the rejection of the Bid.

**END SECTION**

**DISTRIBUTION: (via email)**

All Plan Holders  
Kate Mowbray, Wastewater Technician  
File